BUILDING PERMIT

City of Aurora, Colorado

285107

No.: 2007-209099-000-00 CT

Date: December 26, 2007

Address of Job: 1501 S POTOMAC ST

Contractor: JE DUNN CONSTRUCTION COMPANY

License No.:

Work: SET 20 100# PROPANE CYLINDERS FOR TEMPORARY HEAT WITH CRASH PROTECTION

Conditions: OK FOR COUNTER PER BRAD K ----- STAGING AREA TO REMAIN WITHIN FENCED SECTION OF PROJECT ----- MEDICAL CENTER OF AURORA NO STRUCTURAL INSP NECESSARY

Inspections: ~~Structural~~ Fuel Tank / Lines

Call o

This permit has been issued for compliance using the

Other inspections may be required. Additional inspections for Zoning, Grading, and Engineering may be required before a Certificate of Occupancy can be issued. Record passed inspections on the reverse of this card.

Construction Type:		Occupancy Group:	
Plan Location:		C of O Required	
Contract Amount:	$1,500.00	Taxable Amount:	$750.00

FEES PAID:

Permit Fee	$54.00
Bldg. Use Tax	$28.13
Arap. County Open Space Bld Us	$1.79
Arap. County Transactional Fee	$0.09
TOTAL FEES:	***$84.01***

COLORADO

07 DEC 26 AM 10:48

Other fees may be due before a Certificate of Occupancy or Compliance can be issued. Utility fees are billed separately.

Notes to Applicant:

1. For information, call (303) 739-7420. For For inspections, call (303) 739-7416 one day in advance. All Inspection Requests must be called by 4:00 p.m. of the prior day. The PERMITTEE accepts FULL responsibility for all work done under this permit. All work must be done in accordance with all applicable building codes.

2. Permit is not valid unless signed by Permittee and Permit Fee and Use Taxes are paid in full.

3. Building Permits expire automatically after 180 days unless inspections are requested, or if the time between inspections exceeds 180 days. Requests to extend a permit must be made to the Chief Building Official in writing.

Validation:

_____

Permittee

City of Aurora, Colorado

ADDRESS: 1501 S Potomac St. **PERMIT NUMBER:** 07-209099-CT

ALL GENERAL AND SUB CONTRACTORS ARE REQUIRED TO BE LICENSED

TYPE OF CONTRACTOR	NAME	LICENSE NO.
General		
Concrete		
Waterproofing		
Mason		
Roofing		
Lathing/Gypsum Board		
HVAC		
Electrical (State number)		
Plumbing		
Insulation		
Fire Protection		

NOTE: ✓ ROUGH INSPECTIONS MUST SHOW ON PLUMBING, ELECTRICAL & HVAC BEFORE ROUGH FRAME INSPECTION

Comments	Date	Initials
Under Ground Plumbing		
✓ Rough Plumbing		
Final Plumbing		
Concrete Encased Ground		
✓ Rough Electrical		
Electrical Service		
Final Electrical		
Gas Pipe		
✓ Rough HVAC		
Final HVAC		
Footing ____ Caisson ____ Engineer's Letter ____		
Concrete Reinforcing ____ Engineer's Letter ____		
Foundation Waterproofing ____ Survey ____		
Structural Floor		
Roof/Pre-Roof		
✓ Rough Frame		
Insulation		
Gypboard		
Final Frame		

Life Safety: Sprinkler System ____ Fire Alarm ____
Fire Extinguisher ____ Exit Lights ____
Fire Lanes ____ Misc. FUEL LINES - FINAL

Engineering ____ Grade ____ Zoning ____

TANKS REMOVED 7-2-08 LL

Public Improvement Inspections (303) 739-7350 **Zoning Inspections (303) 739-7449**

FOR BUILDING INSPECTIONS CALL BEFORE 4:00 PM FOR NEXT DAY INSPECTION
(303) 739-7416 OR FAX TO (303) 739-7412

F: dept\development services\Building Division\Shared\Building Forms\Reverse of permit card.doc

BUILDING PERMIT APPLICATION

City of Aurora – Building Codes Division
15151 E Alameda Pkwy, Permit Center 2nd Floor
Aurora, CO 80012 (303) 739-7420
www.auroragov.org/building

Project Address: 1501 S POTOMAC ST Unit # Zip code:
Subdivision/Project Name: AURORA MED CENTER
Contractor: JE DUNN / FERRELLGAS Phone: 303-994-3302
Email: brian.mcclellie ferrellgas.com Fax: 303-287-2505
Owner:
Owner address: Valuation: $1500.00
Email:

DESCRIBE THE WORK YOU WILL BE DOING

Deliver 20# 100# PROPANE CYLINDERS FOR TEMPORARY HEAT.

THIS SECTION FOR NEW HOME CONSTRUCTION ONLY

Model #: Elevation: Foundation Type:

Basement Type: Unfinished: Finished: SF:
Number of Deck(s): Covered: Uncovered: Size of Deck (s):
Concrete Patio(s): Covered: Uncovered: Size of Patio Cover:

MECHANICAL

Heating type: BTU's: Qty: Gas range/oven/cook top: BTU's Qty
AC/Cooler/CFM/Ton: Fireplace: Misc:

PLUMBING

Shower #: Lavatory #: Bathtub #: Water Closet #:
Water heater type: BTU'S: # Misc.:

ELECTRICAL

Electrical Service AMP: Const Meter: Misc.:

◆◆◆◆ THIS SPACE FOR OFFICE USE ONLY ◆◆◆◆

Project Valuation:

Include sprinkler and alarm? ☐ Yes ☐ No

REVIEWS		INSPECTIONS	
☐	Structural	☐	Structural
☐	Mechanical	☐	Mechanical
☐	Plumbing	☐	Plumbing
☐	Electrical	☐	Electrical
☐	Life Safety	☒	Life Safety


Parent Permit RSN: STAND ALONE
Parent Plan Location:
Permit Type: CT
Sub Type: FUEL STORAGE – TANKS – LPG
Plans Examiner: B. KNIGHT
Verify Homeowner:
Change of occupancy/use: ☐ Yes ☐ No


Plan Fee Due $ Intake Date: 12-26-07 Permit # 2007 209099
Balance Due $ 565.64 Plan Location: RSN: 285107


BOARD OF APPEALS - The City of Aurora has created a Building Code and Contractor's Appeals and Standards Board. Applicants have the right to have the board hear appeals of orders, decisions or determinations made by the building official relative to the application and interpretation of the building code. Any application for appeal to the board shall be based on a claim that the true intent of the code or the rules legally adopted thereunder have been incorrectly interpreted, the provisions of the building code do not fully apply or an equally good or better form of construction is proposed.

Signature: Brian McClellie Date: 12/19/07
Print Name: BRIAN MCCLELLIE

20 EA. 100# CYLINDERS FENCED with CRASH protection







20 ea. 100# cylinders
with crash protection and fire extinguisher

Stage Area: 25' from road
5' from trailer

APPROVED
City of Aurora Building Division
Dacrichia
12-19-07
CT